



ALTERNATIVE METHOD: AC POWER TO RETAIL POS & COMPUTER SYSTEMS

Relaxed/Power Conditioned AC Power System. When Preferred AC Power is cost prohibitive, a relaxed AC Power System may be used. The Preferred AC Power System is recommended by DCRS. Careful attention must be given when the Customer selects this Relaxed/Power Conditioned method. If this alternative method is selected, the Customer understands and acknowledges that:

- Approved Ground/Power Conditioners ARE REQUIRED at ALL POS, Computer and Printer equipment locations (EVERY DEVICE on the network). Approved Uninterruptible Power Supplies (UPS) are also required at each system Server.
• All POS Power branch circuits must originate from the same "Non-Dedicated" Power Panel. This Panel, when possible, should be equipped with an "isolated" ground bus that is electrically isolated from the panel frame and must be provided with an insulated equipment grounding conductor (sized the same as the supply conductors) which is installed in the same conduit as the supply conductors from the main or source power panel. The equipment grounding conductor must be terminated on the ground bus in the main or source panel and on the "isolated" ground bus in the "Non-Dedicated" Power Panel.
• In the event multiple main or source AC Power Panels are utilized, ground potential problems could severely degrade the performance of the POS (even with Power Conditioners). Line Drivers or Optical Isolation Devices may be required.
• Any Power Panel supplying heavy equipment should not be selected as the "Non-Dedicated" Power Panel supplying the POS.
• POS Power Circuits must be "dedicated" for the POS equipment only. No equipment other than POS equipment may be supplied by these "dedicated" circuits.
• POS Power Circuits must also be installed in a dedicated ferrous conduit system. No circuits, other than POS, may exist in this dedicated conduit. Flexible, rigid, or Greenfield metallic conduit is acceptable. Aluminum conduit is not acceptable.
• Each "dedicated" circuit must include a full size (same as supply conductors) insulated equipment grounding conductor. When possible, the ground conductor should be terminated at the "isolated" ground bus in the Panel.
• All POS Power receptacles shall be the isolated ground type and shall be installed in accordance with the specifications contained in the separate DCRS "AC POWER REQUIREMENTS: RETAIL POINT OF SALE & COMPUTER SYSTEMS" document.
• DCRS provides only premium level Power Conditioning products. Base or mid level products cannot be used.
• Failure to follow these specifications will result in the voiding of hardware warranty and/or coverage under a support plan. DCRS Solutions is not liable under any circumstances for any damages, claims, losses or expenses, arising from, related to, or caused by AC Power related disturbances.

I have read and understand the above specifications and conditions, and I agree to comply with these requirements prior to any installation of any computer devices from DCRS Solutions. If clarification is needed, please contact the DCRS Customer Service Manager by calling 314-739-6666 or 1-800-231-0166.

COMPANY NAME _____ DATE _____

AUTHORIZED SIGNATURE _____ TITLE _____

ALTERNATIVE POWER TO RETAIL POS & COMPUTER SYSTEM

Oneac ONE GROUND / POWER CONDITIONER Conversion Table

Sample DCRS Product	Req. Oneac Product
Micros Ws4 or Ws5 w/Thermal Printer	.62 amp, 2 outlets
Micros KBWs4 w/Thermal Printer	.62 amp, 2 outlets
Micros Autocut Printer (2 if close together)	.62 amp, 2 outlets
Micros KDS USB Controller w/Display	1.0 amp, 2 outlets
Micros 2010 PCWs w/Thermal or Autocut Printer	1.0 amp, 2 outlets
Micros Eclipse PCWs w/Thermal or Autocut Printer	1.0 amp, 2 outlets
HP rp3000 w/LCD/Thermal Printer/Small Scanner	2.0 amp, 4 outlets
IBM SurePOS 500 w/Thermal Printer/Small Scanner	2.0 amp, 4 outlets
HP rp57xx Server w/LCD (NO Printer)	2.0 amp, 4 outlets
HP 150/350 Server w/LCD (NO Printer)	3.0 amp, 4 outlets
Micros Ws4/5 w/Thermal Printer/Small Scale/Coin Dispenser	3.0 amp, 4 outlets
Laser Printer (alone)	4.6amp, 4 outlets
HP Server w/LCD/Laser Printer	6.2 amp, 4 outlets

SA019